



Test Report

Customer Details

Bitumat Co Ltd.
PO Box: 7487, Dubai, UAE

Report No. WD-R-210713-0470



Request No. : WD-Q-210713-0108

Received Date : 13/07/2021

Sample No. : WD-S-210713-0441

Sampling Date : 13/07/2021

Report Date. : 18/07/2021

Analysis Start Date. : 13/07/2021

Analysis End Date. : 18/07/2021

Sample Location. :

Sampled By : Client representative

Sample Description : Bitumat Concrete Primer

Sample Identification : Bitumat Concrete
Primer

Parameters	Test Methods	Units	Results
Volatile Organic Compound(VOC)	USEPA 24	g/L	330

Remarks :None

Analyst	Reviewed By	Method Variation
AS	AP	None

Signed for and on behalf of Wimpey Laboratories



Dr. Aneesh

Chemist

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WRF1-P-002 Issue No.:01 Rev No:00 Issued Date:20-05-2020

- End of Text -